

7151.6700 OVERFILL PROTECTION.

Subpart 1. **General.** Except as otherwise provided in subpart 2, owners and operators shall provide overfill protection, as provided in part 7151.5700, for all tank systems.

Subp. 2. **Exclusions.** A secondary containment area for tanks or tank systems which is constructed to a 1×10^{-7} centimeters per second permeability standard and meets the requirements of part 7151.5400 or 7151.6400, subparts 1 to 4, is excluded from the requirements of this part.

Subp. 3. **Timing of compliance.** Effective November 1, 2003, overfill protection shall be implemented pursuant to part 7151.5700.

Statutory Authority: *MS s 115.03*

History: *23 SR 883; 25 SR 556*

Published Electronically: *October 2, 2007*