

7151.8300 REACTIVATING OUT-OF-SERVICE ABOVEGROUND STORAGE TANK SYSTEMS.

The owner or operator shall, prior to placing an inactive aboveground storage tank system back into service, thoroughly inspect and test the aboveground storage tank system pursuant to part 7151.5200, subpart 3.

Statutory Authority: *MS s 115.03*

History: *23 SR 883*

Published Electronically: *October 2, 2007*