REVISOR

7500.3500 SMOKELESS PROPELLANTS.

Subpart 1. **Restricted scope.** This part does not apply to the transportation of smokeless propellants governed by Code of Federal Regulations, title 49, parts 100 to 199 (1983).

Subp. 1a. **Approved container required.** Smokeless propellants must be stored in shipping containers approved by the Department of Transportation in Code of Federal Regulations, title 49, parts 100 to 199 (1983).

Subp. 1b. **Transportation of certain quantities.** Quantities of smokeless propellants of 25 pounds or less in shipping containers approved by the Department of Transportation in Code of Federal Regulations, title 49, parts 100 to 199 (1983), may be transported in a passenger vehicle.

Quantities in excess of 25 pounds but not exceeding 50 pounds that are transported in a passenger vehicle must be in a portable magazine having wooden walls of at least one-inch nominal thickness.

Transportation of quantities in excess of 50 pounds is prohibited in vehicles transporting passengers.

Transportation of quantities in excess of 50 pounds in other than passenger vehicles must comply with Department of Transportation regulations in Code of Federal Regulations, title 49, parts 100 to 199 (1983). In addition, warning placards must be prominently displayed when more than 250 pounds are being transported.

Subp. 2. Storage of propellants intended for personal use. Smokeless propellants intended for personal use in quantities not to exceed 20 pounds may be stored in residences. Quantities in excess of 20 but not exceeding 50 pounds must be stored in a wooden box or cabinet having walls of at least one-inch nominal thickness.

Subp. 3. **Commercial displays and stocks.** Not more than 20 pounds of smokeless propellants, in containers of one-pound maximum capacity, may be displayed in commercial establishments. Commercial stocks of smokeless propellants greater than 20 pounds but not more than 100 pounds must be stored in approved wooden boxes having walls of at least one-inch nominal thickness. Not more than 50 pounds are permitted in any one box.

Commercial stocks in quantities not to exceed 750 pounds must be stored in storage cabinets having wooden walls of at least one-inch nominal thickness. Not more than 400 pounds are permitted in any one cabinet.

Subp. 4. **Quantities over 750 pounds.** Quantities in excess of 750 pounds must be stored in magazines constructed and located as specified in part 7500.0800.

Statutory Authority: MS s 299F.71 to 299F.83

History: 11 SR 6

Published Electronically: July 26, 2007