

**7511.0909 SECTION 909, SMOKE CONTROL SYSTEMS.**

Subpart 1. **IFC Section 909.4.7.** IFC Section 909.4 is amended by adding a section to read:

**909.4.7 Door opening force.** With any of the design methods allowed by Section 909, the door opening force, latch release, and set-in-motion force shall comply with Section 1008.1.2 requirements when the system is in smoke control mode.

Subp. 2. **IFC Section 909.22.** IFC Section 909 is amended by adding a section to read:

**909.22 High-rise and covered mall smoke-exhaust systems.** High-rise buildings and covered mall buildings exceeding 50,000 square feet (4645 m<sup>2</sup>) in floor area, excluding anchor stores, shall be equipped with a post-fire smoke exhaust system installed and maintained in accordance with the Building Code.

**Statutory Authority:** *MS s 299F.011*

**History:** *32 SR 10*

**Published Electronically:** *October 11, 2007*