

7511.2306 [Renumbered 7511.3206]

7511.2306 SECTION 2306, FLAMMABLE AND COMBUSTIBLE LIQUID MOTOR FUEL-DISPENSING FACILITIES.

Subpart 1. **IFC section 2306.2.3.** IFC section 2306.2.3 is amended by adding exceptions to Item 1 to read:

Exceptions:

1. When approved by the fire chief, other aboveground tanks that comply with Chapter 57 are allowed to be used for outside, above-grade storage and dispensing of Class I liquids, provided the tanks are located in accordance with Table 2306.2.3.
2. Existing nonprotected tanks designed, fabricated, and constructed in accordance with Section 5704.2.7 and not exceeding 6,000 gallons individual capacity and 18,000 gallons aggregate capacity are allowed to be located not less than 30 feet from the nearest dispenser and the nearest side of any public way, property line, building, or combustible storage located on the same property.

Subp. 2. **IFC section 2306.2.3.** IFC section 2306.2.3 is amended by numbering the exception to Item 2 and by adding a second exception, so that the exceptions to Item 2 read as follows:

Exceptions:

1. Other aboveground tanks that comply with Chapter 57 where approved by the fire code official.
2. Existing nonprotected tanks designed, fabricated, and constructed in accordance with Section 5704.2.7 and not exceeding 10,000 gallons individual capacity and 30,000 gallons aggregate capacity are allowed to be located not less than 30 feet from the nearest dispenser and the nearest side of any public way, property line, building, or combustible storage located on the same property.

Subp. 3. **IFC section 2306.2.3.** IFC section 2306.2.3 is amended by adding Items 6 and 7 to read:

6. For operations not open to the public and for resort operations serving registered guests only, which dispense Class I liquids from one tank having a capacity of 560 gallons (2,120 L) or less, having the dispenser located on or adjacent to the tank is permitted. Such tanks shall be located in accordance with Table 2306.2.3.
7. For operations not open to the public and for resort operations serving registered guests only, which dispense Class II liquids from two tanks having a capacity of up to 1,000 gallons (3,785 L) each, having the dispenser located on or adjacent to the tank is permitted. Such tanks shall be located in accordance with Table 2306.2.3.

Subp. 4. **IFC Table 2306.2.3.** IFC Table 2306.2.3 is amended by modifying footnote "a" to read:

^a When approved by the fire chief, dispensing devices are permitted to be installed on top of or adjacent to protected aboveground tanks or tanks in vaults.

Statutory Authority: *MS s 299F.011; 326B.02*

History: *32 SR 10; 40 SR 1437; 44 SR 610*

Published Electronically: *April 16, 2020*