

7835.2100 ELECTRICAL CODE COMPLIANCE.

Subpart 1. **Compliance; standards.** The interconnection between the qualifying facility and the utility must comply with the requirements in the most recently published edition of the National Electrical Safety Code issued by the Institute of Electrical and Electronics Engineers. The interconnection is subject to subparts 2 and 3.

Subp. 2. **Interconnection.** The qualifying facility is responsible for complying with all applicable local, state, and federal codes, including building codes, the National Electrical Code (NEC), the National Electrical Safety Code (NESC), and noise and emissions standards. The utility must require proof that the qualifying facility is in compliance with the NEC before the interconnection is made. The qualifying facility must obtain installation approval from an electrical inspector recognized by the Minnesota State Board of Electricity.

Subp. 3. **Generation system.** The qualifying facility's generation system and installation must comply with the American National Standards Institute/Institute of Electrical and Electronics Engineers (ANSI/IEEE) standards applicable to the installation.

Statutory Authority: *MS s 216A.05; 216B.08; 216B.164*

History: *9 SR 993; 40 SR 348*

Published Electronically: *October 12, 2015*