

7835.5400 PERMITTING ENTRY.

If the particular configuration of the qualifying facility precludes disconnection or testing from the utility side of the interconnection, the qualifying facility must make equipment available and permit electric and communication utility personnel to enter the property at reasonable times to test isolation and protective equipment, to evaluate the quality of power delivered to the utility's system, and to test to determine whether the qualifying facility's generating system is the source of any electric service or communication systems problems. The utility remains responsible for its personnel.

Statutory Authority: *MS s 216A.05; 216B.08; 216B.164*

History: *9 SR 993*

Published Electronically: *February 28, 2000*