

1.1 **Board of High Pressure Piping Systems**

1.2 **Adopted Permanent Rules Governing High Pressure Piping Systems**

1.3 **5230.0005 DEFINITIONS.**

1.4 [For text of subps 1 to 15, see M.R.]

1.5 Subp. 15a. **Registered unlicensed individual.** "Registered unlicensed individual"
1.6 means an individual who is:

1.7 A. employed in the trade of the practical construction and installation of high
1.8 pressure piping and appurtenances by a licensed high pressure piping business; and

1.9 B. registered with the department under part 5230.0035.

1.10 [For text of subps 16 and 17, see M.R.]

1.11 **5230.0220 BIOPROCESS PIPING.**

1.12 Subpart 1. **ASME BPE.** All bioprocess piping must meet the requirements of
1.13 ASME BPE. For purposes of this chapter, "ASME BPE" means the 2012 edition of the
1.14 Bioprocessing Equipment Standard adopted and published by ASME, ~~Three~~ Two Park
1.15 Avenue, New York, New York 10016. ASME BPE is incorporated by reference and made
1.16 part of the code for high pressure piping systems. ASME BPE is not subject to frequent
1.17 change and a copy of ASME BPE is available in the office of the commissioner of labor
1.18 and industry and at the State Law Library, 25 Rev. Dr. Martin Luther King Jr. Blvd., Saint
1.19 Paul, Minnesota 55155.

1.20 [For text of subp 2, see M.R.]

1.21 **5230.0260 SCOPE.**

1.22 Valves, fittings, and piping for boilers, as prescribed in the ASME Code for Power
1.23 Boilers, are within the scope for this code but provisions of the ASME Code for Power
1.24 Boilers shall govern where they exceed corresponding requirements of this code. For
1.25 purposes of this chapter, "ASME Code for Power Boilers" means the 2013 edition of

2.1 the ASME Boiler and Pressure Vessel Code, section I, as adopted and published by
2.2 ASME, ~~Three~~ Two Park Avenue, New York, New York 10016. The ASME Code for
2.3 Power Boilers is incorporated by reference in the code for steam or heating media piping
2.4 systems. The ASME Code for Power Boilers is not subject to frequent change and a copy
2.5 is available in the office of the commissioner of labor and industry and at the State Law
2.6 Library, 25 Rev. Dr. Martin Luther King Jr. Blvd., Saint Paul, Minnesota 55155.

2.7 Economizers, heaters, tanks, and other pressure vessels are outside the scope of this
2.8 code, but connecting piping shall conform to the requirements herein specified.

2.9 **5230.0265 ADOPTION OF ASME B31.1 BY REFERENCE.**

2.10 For purposes of this chapter, "ASME B31.1" means the 2012 edition of the standard for
2.11 power piping, as approved and published by ASME, ~~Three~~ Two Park Avenue, New York,
2.12 New York 10016. ASME B31.1 is incorporated by reference and made part of the code for
2.13 steam or heating media piping systems, except as amended in this chapter. Portions of this
2.14 chapter reproduce text from ASME B31.1. ASME B31.1 is not subject to frequent change
2.15 and a copy of ASME B31.1 is available in the office of the commissioner of labor and
2.16 industry and at the State Law Library, 25 Rev. Dr. Martin Luther King Jr. Blvd., Saint
2.17 Paul, Minnesota 55155. ASME B31.1 is copyright by ASME. All rights reserved.

2.18 **5230.0275 CHAPTER I, SCOPE AND DEFINITIONS.**

2.19 Subpart 1. **Section 100.1.2.** The first paragraph of part (A) of ASME B31.1, section
2.20 100.1.2 is amended to read as follows:

2.21 (A) This code covers boiler external piping as defined below for power boilers and
2.22 high temperature, high pressure water boilers in which: steam or vapor is generated at a
2.23 pressure of more than 15 p.s.i. gauge; and high temperature water or other medium used
2.24 for heating is generated at pressures exceeding 30 p.s.i. gauge and temperatures exceeding
2.25 250 degrees Fahrenheit (120 degrees Celsius).

3.1 Subp. 2. **Section 100.1.3.** Subparagraph (F) of ASME B31.1, section 100.1.3,
3.2 is deleted.

3.3 **5230.5001 INCORPORATIONS BY REFERENCE.**

3.4 Subpart 1. **ANSI/IIAR 2.** For purposes of this chapter, "ANSI/IIAR 2" means the
3.5 2008 revision with addendums A and B of the standard for Equipment, Design, and
3.6 Installation of Closed-Circuit Ammonia Mechanical Refrigerating Systems, as approved
3.7 by the American National Standards Institute and as published by the International
3.8 Institute of Ammonia Refrigeration, 1110 North Glebe Road, Suite 250, Arlington,
3.9 Virginia 22201. ANSI/IIAR 2 is incorporated by reference and made part of the code
3.10 for ammonia refrigeration systems, except as amended in this chapter. Portions of this
3.11 chapter reproduce text from ANSI/IIAR 2. ANSI/IIAR 2 is not subject to frequent change
3.12 and a copy of ANSI/IIAR 2 is available in the office of the commissioner of labor and
3.13 industry and at the State Law Library, 25 Rev. Dr. Martin Luther King Jr. Blvd., Saint
3.14 Paul, Minnesota 55155. ANSI/IIAR 2 is copyrighted by the International Institute of
3.15 Ammonia Refrigeration. All rights reserved.

3.16 Subp. 2. **ASME B31.5.** For purposes of this chapter, "ASME B31.5" means the
3.17 2013 revision of the standard for ammonia refrigeration piping as approved and published
3.18 by ASME, ~~Three~~ Two Park Avenue, New York, New York 10016. ASME B31.5 is
3.19 incorporated by reference and made part of the code for ammonia refrigeration piping.
3.20 ASME B31.5 is not subject to frequent change and a copy of ASME B31.5 is available in
3.21 the office of the commissioner of labor and industry and at the State Law Library, 25 Rev.
3.22 Dr. Martin Luther King Jr. Blvd., Saint Paul, Minnesota 55155.

3.23 **5230.5007 SECTION 11, OVERPRESSURE PROTECTION DEVICES.**

3.24 [For text of subps 1 to 3, see M.R.]

3.25 Subp. 4. **Section 11.3.3.** ANSI/IIAR 2, section 11.3.3 of addendum A, is amended
3.26 to read as follows:

