

299F.014 RULES FOR CERTAIN PETROLEUM STORAGE TANKS; TANK VEHICLE PARKING.

(a) Any rule of the commissioner of public safety that adopts provisions of the State Fire Code relating to aboveground tanks for petroleum storage that are not used for dispensing to the public is superseded by Minnesota Rules, chapter 7151, in regard to: secondary containment, substance transfer areas, tank and piping standards, overfill protection, corrosion protection, leak detection, labeling, monitoring, maintenance, record keeping, and decommissioning. If Minnesota Rules, chapter 7151, does not address an issue relating to aboveground tanks for petroleum storage that are not used for dispensing to the public, any applicable provision of the State Fire Code applies.

(b) A motorized tank vehicle used to transport petroleum products may be parked within 500 feet of a residence if the vehicle is parked at an aboveground tank facility used for dispensing petroleum into cargo tanks for sale at another location.

History: 1999 c 203 s 8; 2005 c 136 art 9 s 5